

NATURAL	RECOMMENDED
NATURAL OVERFLOW 891.7	
NORMAL LEVEL 890.7	FLOOD RESERVE CONTROLLED OUTFLOW 890.0
EXTREME LOW LEVEL 888.0	PUMPING

BENNETT

NATURAL	RECOMMENDED
EXTREME HIGH WATER 890.0	
ORDINARY HIGH WATER 888.3	888.0
NORMAL LEVEL 887.0	FLOOD RESERVE CONTROLLED OUTFLOW 886.5
EXTREME LOW LEVEL 884.6	PUMPING

OWASSO

NATURAL	RECOMMENDED
EXTREME HIGH WATER 887.7	
ORDINARY HIGH WATER 884.4	884.5
NORMAL LEVEL 883.5	FLOOD RESERVE CONTROLLED OUTFLOW 883.0
EXTREME LOW LEVEL 880.5	PUMPING

SNAIL

NATURAL	RECOMMENDED
	881.5
NORMAL LEVEL 881.0	FLOOD RESERVE CONTROLLED OUTFLOW
DITCH OUTLET 880.5	
EXTREME LOW LEVEL 879.3	PUMPING

GRASS

ST. PAUL WATER DEPARTMENT
LAKES
VADNAIS

MAINTAIN LARGE FLOOD RESERVE TO CONSERVE
OVERFLOW FOR BENEFICIAL USE.