

EXISTING	RECOMMENDED
EXTREME HIGH WATER 927.0	
EXISTING SPILLWAY 926.2	
NORMAL LEVEL 924.5	FLOOD RESERVE CONTROLLED OUTFLOW
	PUMPING
EXTREME LOW WATER 921.3	

WHITE BEAR

EXISTING	RECOMMENDED
EXISTING SPILLWAY 911.0	
PROBABLE EXTREME LOW WITH NO PUMPING 909.5	FLOOD RESERVE CONTROLLED OUTFLOW
	PUMPING
EXTREME LOW LEVEL 906.6	

BALD EAGLE

EXISTING	RECOMMENDED
EXTREME HIGH WATER 920.0	
NORMAL LEVEL 918.4	FLOOD RESERVE CONTROLLED OUTFLOW
	PUMPING
EXTREME LOW LEVEL 916.0	

BIRCH

ST. PAUL WATER DEPARTMENT
LAKES
OTTER BLACK

MAINTAIN LARGE FLOOD RESERVE TO CONSERVE OVERFLOW FROM ABOVE LAKES FOR BENEFICIAL USE.

EXISTING	RECOMMENDED
EXISTING SPILLWAY 859.0	
	FLOOD RESERVE CONTROLLED OUTFLOW
	PUMPING
EXTREME LOW LEVEL 856.6	

**KOHLMAN
GERVAIS
KELLER
PHALEN**

EXISTING	RECOMMENDED
NATURAL OVERFLOW 840.8	
	FLOOD RESERVE CONTROLLED OUTFLOW
	PUMPING
EXTREME LOW LEVEL 839.13	

Mc CARRONS

PREVENT ESCAPE OF WATER INTO RIVER SO FAR AS POSSIBLE

MISSISSIPPI RIVER